



SOLAR RATING  
& CERTIFICATION  
CORPORATION™

## ICC-SRCC™ LISTING

### ICC-SRCC™ Solar Thermal Listing Program

**Listing Number: SRCC-19002**

**Effective Date: October 01, 2020**

*This listing is subject to renewal in one year.*

---

[www.solar-rating.org](http://www.solar-rating.org) (888) 422-7233 ICC-SRCC  
3060 Saturn Street, Suite 100  
Brea, CA 92821

*A Program of the ICC Evaluation Service (ICC-ES) – [www.icc-es.org](http://www.icc-es.org)*

---

**CSI:** DIVISION: 22 00 00 – PLUMBING  
Section: 22 33 30.23 – Solar Domestic Water Heater System

DIVISION: 23 00 00 – HEATING  
Section: 23 56 13 – Heating Solar Collectors

#### **Product certification program:**

The ICC-SRCC Solar Thermal Standard Listing Program is conducted in accordance with the latest version of the ICC-SRCC *Solar Thermal Listing Program Guidelines*. The program includes evaluation of samples and manufacturer's quality assurance systems to assess continued compliance with applicable codes and standard.

**Products:** Solar Thermal System and Solar Thermal Collectors

**Listee:** GE Appliances, A Haier Company  
4000 Buechel Bank Road  
Louisville, KY 40225  
USA

#### **Compliance with the following codes, standards and criteria:**

- ❖ 2021 International Plumbing Code® (IPC)
- ❖ 2021 International Green Construction Code® (IgCC)
- ❖ 2015 Uniform Solar Energy Code® (USEC)\*
- ❖ 2015 Uniform Plumbing Code® (UPC)\*
- ❖ ICC 901/SRCC 100-2020, Solar Thermal Collector Standard
- ❖ ICC 900/SRCC 300-2020, Solar Thermal Systems Standard

\* *Uniform Plumbing Code and Uniform Solar Energy Code are copyrighted publications and trademarks of the International Association of Plumbing and Mechanical Officials (IAPMO)*



**Models:**

The solar heating and/or cooling products listed below have been evaluated by the Solar Rating & Certification Corporation (ICC-SRCC™), an ISO/IEC 17065 accredited and EPA recognized Certification Body, in accordance with the *ICC-SRCC Solar Heating & Cooling Code and Standard Listing Program Operating Guidelines*, and has been listed by the ICC-SRCC to the codes and standards above. This award of listing is subject to all terms and conditions of the *ICC-SRCC Solar Heating & Cooling Code & Standard Listing Program Agreement* and the documents incorporated therein by reference. Where solar collectors are listed, all sizes of the collector model are listed.

**Solar Thermal Collectors**

Collector Type	Brand Name	SRCC OG-100 Certification Number*
ICS Glazed	GE GT25C	<a href="#">10002088</a>
ICS Glazed	GE GT40C	<a href="#">10002087</a>
ICS Glazed	GE GT50C	<a href="#">10002086</a>

**Solar Water Heating Systems**

Brand Name	Model Number	SRCC OG-300 Certification Number*
GeoSpring™ Solar	GT25C10BAM-TG	30004294
GeoSpring™ Solar	GT40C10BAM-TG	30004293
GeoSpring™ Solar	GT50C10BAM-TG	30004292
GeoSpring™ Solar	GT25C10BAM-E	30004291
GeoSpring™ Solar	GT40C10BAM-E	30004290
GeoSpring™ Solar	GT50C10BAM-E	30004289
GeoSpring™ Solar	GT25C10BAM-G	30004288
GeoSpring™ Solar	GT40C10BAM-G	30004287
GeoSpring™ Solar	GT50C10BAM-G	30004286

\* Certifications to the ICC-SRCC OG-100 & OG-300 programs are available on the ICC-SRCC website at [www.solar-rating.org](http://www.solar-rating.org)

**Installation:**

Solar thermal systems and solar collectors must be installed in accordance with the manufacturer’s published installation instruction, the applicable code(s) and this listing. Where differences exist, the instructions in this listing must govern.

All individual components of the system which may require periodic examination, adjustment, service and or maintenance must be easily and safely accessible by the owner in accordance with the codes in force at the installation site.



Interconnection of the auxiliary system to the solar energy system shall be made in a manner which will not result in excessive temperature or pressure in the auxiliary system or bypassing of safety devices of the auxiliary system.

Collectors and support shall be installed in such a manner that water flowing off the collector will not damage the building or cause premature erosion of the roof. Water tanks located in or above the living space shall be installed on a drip pan with a drain line to safely remove any excess liquid.

Structural supports shall be selected and installed in such a manner that thermal expansion of the collector and piping will not cause damage to the collector, structural frame or building. Hangers shall provide adequate support and correct pitch of piping and shall be designed to avoid compressing or damaging any pipe insulation material.

### Conditions of Listing:

1. System components shall be installed in accordance with the manufacturer's published installation instructions and the applicable code(s).
2. System components requiring access for maintenance and inspection shall be install to provide required access in accordance with manufacturer's instructions and local codes.
3. Systems and components shall be installed in accordance with the requirements of ICC 900/SRCC 300, Section 503 of the IPC, Chapter 5 of the UPC and Chapter 3 of the USEC and must provide provision for bypass, adjustment or override controls as are required to facilitate installation, startup, operation, shutdown and maintenance.
4. Systems utilizing a non-potable heat transfer fluid must not be connected to the potable water system except through the use of approved devices such as backflow preventers or double-walled heat exchangers.
5. Systems shall be sized in accordance with the demand, manufacturer's requirement, and local codes.
6. Systems shall not be installed below flood elevation level.
7. Systems shall only be used with water or aqueous solutions of ethylene glycol or propylene glycol up to 100% concentration per manufacturer's requirements.
8. Relief valves shall discharge to an approved receptor for disposal in accordance with local codes and requirements.
9. Each installation must be pressure-tested for leaks in the presence of the code official or code official's designated representative.
10. When installation is in fire-resistance-rated assemblies, evidence of compliance with IBC Section 712 (penetrations) must be provided to the code official for approval.
11. System components shall be assembled such that fire-stopping shall be possible at the time of installation, if required by local codes and ordinances.
12. Devices and components shall not reduce or increase humidity, temperature or thermal radiation beyond acceptable levels or interfere with required headroom or air circulation space.
13. Neither wind loading nor the additional weight of filled collectors shall exceed the live or dead load ratings of the building, roof, roof anchorage, foundation or soil. Collector supports shall not impose undue stresses on the collectors. The design load shall be as specified by the codes in force at the installation site and shall include and additional load due to snow accumulation for applicable locations.
14. Piping should be sloped toward drain ports with a drainage slope of no less than 2 cm of vertical drop for each meter of horizontal length (1/4 inch per foot). Underground piping shall be installed to withstand surface loads. The trenches and backfill shall be free of sharp objects in contact with the pipe.
15. Field-applied pipe and tank insulation shall comply with local code requirements for thermal insulation value, flame spread, smoke development and finishing.
16. System components shall be compatible with contacting fluids. Components and devices contacting potable water shall



comply with NSF 61 and Federal Safe Drinking Water Act requirements for lead content.

17. Devices and components are manufactured by Solpal, Inc. in San Diego CA under a quality control program with surveillance inspection every other year conducted in accordance with the requirements of ICC-SRCC.

**Marking:**

Models listed above were evaluated to the codes and standards listed in accordance with *the ICC-SRCC Solar Heating & Cooling Code Listing Program Guidelines* and are eligible to display the following mark as governed by the *ICC-SRCC Solar Heating & Cooling Code Listing Program Agreement* and *the ICC-SRCC Trademark, Certification Mark and Certificate Policy*.



Each device or component shall also be permanently marked with manufacturer's name or trademark, model name and/or number, recommended working fluids, maximum working temperature and pressure, and recommended flow rate(s).

Any operation, maintenance and installation instruction manuals from the manufacturer shall be supplied with the pump station. Supplier's contact information shall be included with these documents.

*Listings are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the listing or a recommendation for its use. There is no warranty by the Solar Rating and Certification Corporation, express or implied as to any finding or other matter in this listing, or as to any product covered by the listing. This document must be reproduced in its entirety.*