SOLAR RATING & CERTIFICATION CORPORATION™

An ICC Evaluation Service Program

OG-300 Solar Water Heating System Certification

No./30004383

Issued: December 15, 2023

Expiration Date: November 01, 2027

www.solar-rating.org | **(800) 423-6587** | **(562) 699-0543**

CERTIFICATION HOLDER:	**EVALUATION SUBJECT**	
Heliodyne, Inc. 4910 Seaport Evenue Richmond, CA 94804 USA www.heliodyne.com	**BRAND:**	HELIOPAK
	MODEL:	HPAK 1 410 GT 120 ACD Z
	TYPE:	Pumped, Indirect

PRODUCT CERTIFICATION SYSTEM:

The ICC-SRCC OG-300 system certification program includes evaluation and performance ratings for solar water heating systems as established in the *ICC-SRCC Rules for Solar Heating & Cooling Product Listing Reports*. The program also includes periodic factory inspections and surveillance of the manufacturer's quality management system.

COMPLIANCE WITH THE FOLLOWING STANDARD(S): *ICC 900/SRCC 300 – 2020, Solar Thermal System Standard*
ENERGY STAR Residential Water Heater Specification (v.5.0)

SOLAR UNIFORM ENERGY FACTOR (SUEF): *99.0, Low Draw Pattern*

The Solar Uniform Energy Factor (SUEF) is determined through computer modeling per the specification established in *ICC 900/SRCC 300, Appendix B.*

INSTALLATION:

The solar water heating system must be installed in accordance with the manufacturer's published installation instructions. Installation must conform to the requirements of the applicable code and is subject to approval by the code official having jurisdiction. This certification is valid only for a system composed of the components configured as shown in the schematic below:



Copyright © 2026 Solar Rating & Certification Corporation (ICC-SRCC) All rights reserved.

PARTS LIST:

Part	Quantity	Evaluated Component
Collector Option 1	1	Heliodyne, Inc. Model 410 001 (OG-100 2010115A)
Solar Tank	1	State Model SBV-120-1OTS (454 L volume)

IDENTIFICATION:

Certified systems must be identified with the OG-300 certification mark below in accordance with the *Rules for Certification Mark and Certificate Use* and labeled in with the information below per *ICC 900/SRCC 300*:

1. Manufacturer's name and model number.
2. OG-300 system certification number
3. OG-100 collector certification number(s) and quantity.
4. Heat transfer fluid and concentration range.
5. Storage and expansion tank volumes.
6. Relief valve specification and setpoint.
7. Maximum water supply pressure.
8. Maximum solar loop pressure.
9. Flow rate range (where a flow meter is installed).
10. Backup energy rating. For electrical, phase/volts/amps. For gas, minimum pressure.
11. Installation date field (to be entered by the installer in the field).

CONDITIONS:

The certified solar water heating system must comply with the following conditions:

1. Systems must be installed and operated in accordance with the manufacturer's instructions and local code.
2. Systems must include all components installed in the configuration shown in the schematic in the OG-300 certification document.
3. Systems must use one of the OG-100 certified solar collector options from the list above. Where more than one collector is installed in a system, all collectors must be the same model.
4. Systems must utilize heat transfer fluids approved by the manufacturer.
5. Certifications are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use.
6. There is no warranty by ICC-SRCC express or implied, as to any finding or other matter in this certification, or as to any product covered by the certification.
7. This document must be reproduced in its entirety.

REGIONAL RATINGS:

Thermal performance ratings are provided for the system based on computer modeling to standard OG-300 rating conditions and a hot water load of 64.3 gallons per day (243.4 litres per day) at a setpoint of 125°F (51.7°C) for comparison. Performance is given using the following values:

- Annual Solar Fraction (SF_A): The portion of the total conventional hot water heating load (including tank standby losses) provided by solar energy averaged over one year.

- Annual Energy Savings (AES): The projected energy savings over a period of one year for the system compared to a baseline tank-type water heater using the same fuel source.

Results are given for several climate zones throughout North America. Climate zones are as established in *ANSI/ASHRAE 169, Climatic Data for Building Design Standard*. Actual thermal performance and energy savings for an installed system will vary with local conditions, installation details and hot water usage.

Copyright © 2026 Solar Rating & Certification Corporation (ICC-SRCC™), All rights reserved.

UNITED STATES OF AMERICA

OG-300 LOCAL ANNUAL SOLAR WATER HEATING SYSTEM PERFORMANCE

System performance at several geographic locations in the United States corresponding to climate zones as established in ASHRAE 169 is provided below. Ratings are determined using weather data, solar irradiance and water supply temperature over a period of one year for the specific locations listed below. Ratings for locations in California and Hawaii are provided on separate state maps on the following pages.

USA			
Location	**Climate Zone (ASHRAE 169)**	**Solar Fraction (SF_A)**	**Annual Energy Savings (kWh)**
AK – Anchorage	7	0.44	3500
AZ – Phoenix	2B	0.89	4850
CO – Denver	5B	0.75	5200
FL – Tampa	2A	0.84	4470
GA – Atlanta	3A	0.76	4640
MA – Boston	5A	0.64	4370
MO – St. Louis	4A	0.69	4480
MT – Helena	6B	0.62	4580
TX – Dallas-Fort Worth	3A	0.80	4610
WA – Seattle	4C	0.57	3890
WI - Milwaukee	6A	0.61	4340

Copyright © 2026 Solar Rating & Certification Corporation (ICC-SRCC™), All rights reserved.

STATE OF CALIFORNIA

OG-300 LOCAL ANNUAL SOLAR WATER HEATING SYSTEM PERFORMANCE

System performance at several geographic locations in the state of California corresponding to building climate zones as established by the California Energy Commission (CEC) is provided below. Ratings are determined using weather data, solar irradiance and water supply temperature over a period of one year for the specific locations listed below.

STATE OF CALIFORNIA			
Location**	**Climate Zone (ASHRAE 169)***	**Solar Fraction (SF_A)**	**Annual Energy Savings (kWh)**
CCZ 1- Arcata	7	0.62	4210
CCZ 2 – Santa Rosa	6B	0.76	4890
CCZ 3 - Oakland	3C	0.77	4970
CCZ 4 – Sunnyvale	4C	0.78	4990
CCZ 5 – Santa Maria	5C	0.81	5270
CCZ 6 – Los Angeles	3B	0.83	4960
CCZ 7 – San Diego	3B	0.83	4970
CCZ 8 – El Toro	3B	0.85	5110
CCZ 9 – Burbank	3B	0.83	5110
CCZ 10 – Riverside	3B	0.85	5100
CCZ 11 – Red Bluff	3B	0.77	4660
CCZ 12 – Sacramento	3B	0.78	4800
CCZ 13 - Fresno	3B	0.80	4810
CCZ 14 – China Lake	3B	0.87	5000
CCZ 15 – El Centro	3B	0.89	4700
CCZ 16 – Mt. Shasta	7	0.72	4910

** Climate zones are as established in ANSI/ASHRAE 169, Climatic Data for Building Design Standard.*

*** California Building Climate Zones and representative cities are established by the California Energy Commission for use in the CA Title 24 Energy Efficiency Standards.*

Copyright © 2026 Solar Rating & Certification Corporation (ICC-SRCC™), All rights reserved.

HAWAIIAN ISLANDS

OG-300 LOCAL ANNUAL SOLAR WATER HEATING SYSTEM PERFORMANCE

System performance at several geographic locations in the Hawaiian Islands corresponding to climate zones as established in ASHRAE 169 is provided below. Ratings are determined using weather data, solar irradiance and water supply temperature over a period of one year for the specific locations listed below.



STATE OF HAWAII			
Location	**Climate Zone (ASHRAE 169)**	**Solar Fraction (SF_A)**	**Annual Energy Savings (kWh)**
Hawaii Island – Hilo	1	0.81	4200
Honolulu - Oahu Island	1	0.88	4360
Maui Island - Kahului	1	0.87	4320
Hawaii Island - Keahol	1	0.87	4570
Lihue - Kauai Island	1	0.86	4370
Ho'olehua - Molokai Island	1	0.87	4330

Copyright © 2026 Solar Rating & Certification Corporation (ICC-SRCC™), All rights reserved.

CANADA

OG-300 LOCAL ANNUAL SOLAR WATER HEATING SYSTEM PERFORMANCE

System performance at several geographical locations in Canada corresponding to climate zones as established in ASHRAE 169 is provided below. Ratings are determined using weather data, solar irradiance and water supply temperature over a period of one year for the specific locations listed below. The local annual ratings are provided for a 243 L/day (64.3 gal/day) hot water load.

CANADA			
Location	**Climate Zone (ASHRAE 169)**	**Solar Fraction (SF_A)**	**Annual Energy Savings (kWh)**
AB – Edmonton	5	0.60	4660
NS – Halifax	7A	0.55	3970
ON - Thunder Bay	7A	0.61	4370
QC - Quebec City	5	0.57	4370
MB – Winnipeg	7A	0.58	4620
AB – Calgary	7A	0.62	4820
BC - Vancouver	7	0.57	4040

Copyright © 2026 Solar Rating & Certification Corporation (ICC-SRCC™), All rights reserved.

CENTRAL AMERICA AND CARIBBEAN REGION

OG-300 LOCAL ANNUAL SOLAR WATER HEATING SYSTEM PERFORMANCE

System performance at several geographic locations in Central America and the Caribbean region corresponding to climate zones as established in ASHRAE 169 is provided below. Ratings are determined using weather data, solar irradiance and water supply temperature over a period of one year for the specific locations listed below.

CENTRAL AMERICA & CARIBBEAN REGION			
Location	**Climate Zone (ASHRAE 169)**	**Solar Fraction (SF_A)**	**Annual Energy Savings (kWh)**
USVI – Charlotte Amalie	1	0.91	4910
Barbados - Christ Church	1	0.89	4330
Costa Rica - San Jose	1	0.88	6020
Jamaica – Kingston	1	0.90	4370
Mexico – Monterrey	2	0.71	4120
Mexico - Mexico City	2	0.75	5130
Belize - Belize City	1	0.86	4150
Puerto Rico – San Juan	1	0.90	4870

Copyright © 2026 Solar Rating & Certification Corporation (ICC-SRCC™), All rights reserved.